



MAS Certified Green® Certificate of Compliance Low-Emitting Materials

Awarded to:

**H.B. FULLER CONSTRUCTION PRODUCTS, INC. OF
DALTON, GA** 1702 KIMBERLY PARK DRIVE; ZIP CODE: 30721

Category:
Cert. Scheme:

Construction Materials - Flooring Systems
VOC Emissions

Accredited
Standards &
Test Methods:

California Dept. of Public Health Standard Method v1.2 classroom & private office

*Conforms
With:

Criteria of MAS Certified Green® Program	low-emitting materials
LEED v4.1 ID+C, BD+C	low-emitting materials
LEED TVOC Emissions at 14-days	0.5 mg/m ³ or less
CHPS 2019 Core Criteria 3.0 EQ C6.1.1	adhesive & sealant
CHPS 2019 Core Criteria 3.0 EQ C6.1.5	paints & coatings

Certified
Products:

Moisture Vapor Barriers: TEC® LiquiDam™**, CHAPCO® Defender™
** Product tested as representative exemplar of products listed above.

Test Date:

March 5, 2021 Report No.: 2100055 Certificate No.: MAS2100055-01

Valid: March 2021 to March 2022



Testing Cert. # 2925.01
Product Cert. # 2925.02

Product Certifier, MAS Certified Green CT

Laboratory Testing by [Materials Analytical Services, LLC](#) - ISO/IEC 17025:2017
3rd Party Product Certification by [MAS Certified Green®](#) - ISO/IEC 17065:2012

*outside of A2LA accreditation scope

3945 Lakefield Ct. · Suwanee, Ga. · 770-866-3206 · <http://www.mascertifiedgreen.com/>